



Detail Valve Box Installation

Note: Valve box shall not transmit shock or stress to the valve



PLAN



ELEVATION

NOTES
Concrete Pads shall be constructed around all main line valve boxes except within hard paved areas. Concrete Pads shall be constructed around customer service line valve boxes 3" and larger valves.

REVISION	BY	DATE
1	MPS	6/28/03
2	MPS	8/22/03

N. KY. WATER DISTRICT
VALVE BOX AND
VALVE PAD DETAIL

DRAWN BY:
SAR

APPROVED:
RH

DATE:
8/5/2014

STANDARD
DRAWING NO:

105