



DRAWING NOTES

- ① REFER TO DRAWING NO.204 FOR DETAILS OF FIRE BRANCH PIPING.
- ② 1" OR SMALLER DOMESTIC METER TO ALIGN WITH BACKFLOW DEVICE.
- ③ VALVE
- ④ BRACKETS FOR PIPE SUPPORT.
- ⑤ ON 8" AND SMALLER PIPING, TAPS MADE SHALL BE MADE WITH BRONZE SADDLE FOR 1 1/2" OR 2" TAPS.
- ⑥ PRESSURE REDUCING DEVICE

GENERAL NOTES

- 1. SEE DRAWING 202 FOR PIT CONSTRUCTION DETAILS.
- 2. SEE DRAWING 201 FOR PIT MATERIALS SPECIFICATIONS
- 3. SEE DRAWING 203 FOR PIPING SPECIFICATIONS
- 4. ANY PUMPER CONNECTION SHALL BE INSTALLED DOWNSTREAM OF OUTLET VALVE & BACK FLOW DEVICE.
- 5. ANY POST INDICATORS SHALL BE TYPE THAT WILL ATTACH TO WHEEL OPERATOR AND ALLOW OPERATION OF VALVE WITHIN PIT.
- 6. 1" & SMALLER METERS WITH COUPLINGS TO BE PURCHASED FROM NKWSD.
- 7. An approved Approved Backflow Prevention Assembly shall be required on Fire Lines by the following governing bodies: Kentucky Public Service Commission, Kentucky Division of Water, and Kentucky Division of Plumbing.

REVISION	BY	DATE
	ADD 1" OR SMALLER METER	10/08/14
	ADD DOUBLE CHECK ASSEMBLY	11/05/14

N. KY. WATER DISTRICT DUAL SERVICE BRANCH SETTING W/1" & SMALLER METER	DRAWN BY: SAR
	APPROVED: 
	DATE: 8/5/2014
STANDARD DRAWING NO: 206-A	