



DRAWING NOTES

- ① PIPING CLASS 52 WITH FLANGED END WITHIN PIT.
- ② VALVES WITH OUTSIDE SCREW AND YOKE, FLANGED CONNECTIONS. (RESILIENT SEATED VALVES)
- ③ 2.5" OR LARGER COMPOUND METER
- ④ FLANGED COUPLING ADAPTER OVER PLAIN END PIPE FLANGED BY PLAIN END PIPE.
- ⑤ STRAINER
- ⑥ BYPASS LINE SHALL BE EQUALIVANT IN SIZE AS THE FEED LINE OR THE NEXT SIZE SMALLER (3" MINIMUM SIZE)
- ⑦ IF A PRESSURE REGULATOR IS REQUIRED IT SHALL BE INSTALLED AS SHOWN (DWG NO. 201 item No. 1.09)
- ⑧ SHADED AREA DISTRICTS RESPONSIBILITY

GENERAL NOTES

- 1. SEE DRAWING 202 FOR PIT CONSTRUCTION DETAILS.
- 2. SEE DRAWING 201 FOR PIT MATERIALS SPECIFICATIONS.
- 3. SEE DRAWING 203 FOR PIPING SPECIFICATIONS.
- 4. An approved Double Check Valve Assembly shall be required on Fire Lines by the following governing bodies: Kentucky Public Service Commission, Kentucky Division of Water, and Kentucky Division of Plumbing.

REVISION	COMPOUND METER, ETC.	BY DATE	MPA 10/9/90
	NOTE 4-GEN. NOTE		MPA 2/6/82
N. KY. WATER DISTRICT METER SETTINGS 2.5" AND LARGER		DRAWN BY:	SAR
		APPROVED:	<i>RH</i>
		DATE:	8/5/2014
		STANDARD DRAWING NO:	205R