


PLAN



ELEVATION

DRAWING NOTES

- ① REFER TO DRAWING NO. 204 FOR DETAILS OF FIRE BRANCH PIPING.
- ② 2.5" OR LARGER DOMESTIC COMPOUND METER REFER TO DRAWING NO.205 FOR DETAILS OF DOMESTIC SERVICE LINE PIPING.
- ③ FLANGED COUPLING ADAPTER OVER PLAIN END PIPE 1'0" LONG MINIMUM. (OPTIONAL)
- ④ PROVIDE CONCRETE THRUST BLOCKS (SEE DRAWING NO. 104) OR OTHER APPROVED MEANS AS REQUIRED TO RESTAIN JOINTS.
- ⑤ STRAINER

GENERAL NOTES

- 1. SEE DRAWING NO. 202 FOR PIT CONSTRUCTION DETAIL.
- 2. SEE DRAWING NO. 201 FOR PIT MATERIALS SPECIFICATIONS.
- 3. SEE DRAWING NO. 203 FOR PIPING SPECIFICATIONS.
- 4. ANY POST INDICATOR SHALL BE TYPE THAT WILL ATTACH TO WHEEL OPERATOR AND ALLOW OPERATION OF VALVE WITHIN THE PIT.
- 5. ANY PUMPER CONNECTION SHALL BE INSTALLED DOWNSTREAM OF FIRE BRANCH OUTLET VALVE AND ANY BACK FLOW DEVICE.
- 6. SHADED AREA INDICATES WHAT THE PROPERTY OWNER WILL MAINTAIN AFTER THE WARRENTY PERIOD EXPIRES.
- 7. An approved Approved Back flow Prevention Assembly shall be required on Fire Lines by the following governing bodies: Kentucky Public Service Commission, Kentucky Division of Water, and Kentucky Division of Plumbing.

REVISION	BY	DATE

N. KY. WATER DISTRICT DUAL SERVICE BRANCH SETTING W/2.5" & LARGER METER	DRAWN BY: SAR
	APPROVED: 
	DATE: 8/5/2014
STANDARD DRAWING NO: 207R	