



\*\* Taps on mains which utilizes a cathodic protection system shall require an isolation corporation stop

NOTE: Air Release Valve to be centered over water main.  
 Air Release Valves larger than 1" use:  
 vault size 24"x24"  
 lid Ford Type MC 24 &  
 Extension Ring Ext-2 or approved equal.

REVISION	BY	DATE
N. KY. WATER DISTRICT N.KY WATER DISTRICT AIR RELEASE VALE		
DRAWN BY: SAR		
APPROVED: <i>[Signature]</i>		
DATE: 2/1/2021		
STANDARD DRAWING NO: 106		